

**WEST SACRAMENTO FIRE DEPARTMENT**  
2040 Lake Washington Blvd., West Sacramento, CA 95691  
(916) 617-4600

**BUREAU OF FIRE PREVENTION**

---

---

PERMIT REQUIREMENTS FOR

**REPAIR OR RESTORE MOTOR VEHICLES  
FLAMMABLE LIQUID AND LPG-FUELED VEHICLES**

In accordance with Ordinance 07-21, Chapter 22, 34 & 38 CFC and State Statutes

**SECTION I. INFORMATION REQUIRED**

Applicant is required to furnish the following information before a permit may be processed.....Appendix Chapter 1 (105.3.7) CFC

1. Site plans showing location of all hazardous materials.
2. Name and amount of all hazardous materials. Amount to be listed shall be maximums stored at any one time.

**SECTION II. REQUIREMENTS AND LIMITATIONS**

Issuance of this permit is subject to compliance with the listed requirements and approved by field inspection and necessary tests.

**THESE REQUIREMENTS TO BE ON PREMISES AT ALL TIMES.** .....Appendix Chapter 1 (105.3.7) CFC

**GENERAL**

1. Cleaning of parts shall be conducted in listed and approved parts-cleaning machines in accordance with Chapter 34. ....(2211.2.1) CFC
2. Waste oil, motor oil and other Class IIIB liquids shall be stored in approved tanks or containers, which are allowed to be stored and dispensed from inside repair garages. ....(2211.2.2) CFC
3. Crankcase drainings shall be classified as Class IIIB unless otherwise determined by testing. ....(2211.2.2.2) CFC
4. Storage and handling of flammable or combustible liquids shall be in accordance with Chapter 34 CFC. ....(2211.2) CFC
5. Garage floor drains, where provided, shall drain to approved oil separators or traps discharging to a sewer in accordance with the California Plumbing Code. Contents of oil separators, traps and floor drainage systems shall be collected at sufficiently frequent intervals and removed from the premises to prevent oil from being carried into the sewers. ....(2211.2.3) CFC
6. Crankcase drainings and liquids shall not be dumped into sewers, streams or on the ground, but shall be stored in approved tanks or containers in accordance with Chapter 34 until removed from the premises. ....(2211.2.3.3) CFC
7. Self-closing metal cans shall be used for oily waste. ....(2211.2.3.2) CFC
8. Sources of ignition shall not be located within 18 inches of the floor and shall comply with Chapters 3 and 26. ....(2211.3) CFC
9. Smoking and open flames shall be prohibited in areas used for servicing motor vehicles. ....(2211.3.2) CFC
10. Pits and below grade work areas shall be provided with means of egress in accordance with Chapter 10. ....(2211.4.2) CFC
11. Where Class I liquids or LP-gas are stored or used within a building having a basement or pit wherein flammable vapors could accumulate, the basement or pit shall be provided with mechanical ventilation in accordance with the California Mechanical Code, at a minimum rate of 1.5 cubic feet per minute per square foot (cfm/ft<sup>2</sup>) to prevent the accumulation of flammable vapors. ....(2211.403) CFC
12. For vehicles powered by gaseous fuels, the fuel shutoff valves shall be closed prior to repairing any portion of the vehicle fuel system. ....(2211.5) CFC
13. Vehicles powered by gaseous fuels in which the fuel system has been damaged shall be inspected and evaluated for fuel system integrity prior to being brought into the repair garage. The inspection shall include testing of the entire fuel delivery system for leakage. ....(2211.105) CFC
14. Fire extinguishers shall be provided in accordance with Section 906. ....(2211.6) CFC
15. LP-gas storage and handling shall be in accordance with Chapter 38.

**ADDITIONAL COMMENTS AND/OR REQUIREMENTS:**

Fire Prevention Bureau must be notified 24 hours ahead of time for any tests or inspections required by the applicant.

To abide by all pertinent provisions of Local and State Statutes..... Appendix Chapter 1 (105.3) CFC

Application or Permit does not replace any license or permit required by any other agency. .... Appendix Chapter 1 (105.5) CFC