



EXISTING STREET

NEW CONSTRUCTION

NOTES:

A. AS REQUIRED IN DIVISION IV, SECTION 12.09 OF THE STANDARD SPECIFICATIONS:

1. USE BACKFILL METHOD "A" IN EXISTING STREETS.
2. USE BACKFILL METHOD "B" IN NEW CONSTRUCTION WITHIN THE STREET RIGHT-OF-WAY.
3. USE BACKFILL METHOD "C" IN NEW CONSTRUCTION WITHIN NON-STREET RIGHT-OF-WAY.

B. INITIAL BACKFILL SHALL BE MECHANICALLY CONSOLIDATED UNDER THE HAUNCHES OF THE PIPE.

C. FOR WATER MAIN INSTALLATION, SAND SHALL BE PLACED IN LIEU OF CRUSHED ROCK FOR PIPE BEDDING AND INITIAL BACKFILL.

D. PIPE BEDDING SHALL BE A MINIMUM OF 6 INCHES OR D/4 FOR ALL PIPES GREATER THAN 24 INCHES IN DIAMETER.

E. ALTERNATE BACKFILL MATERIAL AND METHODS SHALL BE SUBJECT TO APPROVAL BY THE CITY ENGINEER.

THE CITY OF WEST SACRAMENTO – STANDARD DETAIL

APPROVED BY: Carol [Signature] C-38733 3/31/05
CITY ENGINEER P.E. NO. DATE

REVISION:	
REVISION:	
REVISION:	
REVISION:	

TITLE:
TRENCH BACKFILL
STANDARD
DETAIL #: 110

