



**NOTES**

- A. 6 FOOT SIDEWALKS ARE REQUIRED, WHERE INDICATED IN TABLE 3-1 OF THE DESIGN STANDARDS. 5 FOOT MINIMUM ALL OTHER LOCATIONS.
- B. CROSS SLOPE OF SEPARATED SIDEWALK TO BE 1.5% (1.00% TO 1.75% ALLOWED). LONGITUDINAL GRADE NOT TO EXCEED 5%.
- C. USE OF SEPARATED SIDEWALKS WILL REQUIRE STREET LIGHTING REVIEW IN RELATION TO LANDSCAPE PLAN, AND MAY REQUIRE ADDITIONAL SIDEWALK LIGHTING.
- D. RELATIVE COMPACTION OF SUBGRADE AND BASE MATERIAL UNDER ALL SIDEWALK, CURB AND GUTTER AREAS SHALL BE 95%.

**THE CITY OF WEST SACRAMENTO - STANDARD DETAIL**



APPROVED: Aug. X, 2025

STANDARD  
DETAIL #

**202A**

TITLE:  
**SEPARATED  
(OR DETACHED)  
SIDEWALK  
TRANSITION**

