



①	4,000 PSI MIN CONCRETE
②	CLASS II AB PROCESSED TO 95% RELATIVE COMPACTION (4" THICK UNDER SIDEWALK & 6" MIN UNDER CURB AND BUS TURNOUT PAD) OR PER PROJECT PLANS.
③	6" MIN OF SUB-GRADE OR CLASS II AB PROCESSED TO 95% RELATIVE COMPACTION, OR PER PROJECT PLANS.
④	8" THICK 4,000 PSI MIN CONCRETE OVER 6" OF SUBGRADE OR CLASS 2 AB PROCESSED TO 95% RELATIVE COMPACTION

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #
262 B

TITLE:
**BUS SHELTER
ELEVATION VIEW
(SECTIONS A-A)**

