



1	SEWER MAIN WITH SEWER SERVICE WYE AT 30-45 DEGREES.
2	1/8th BEND AT WYE.
3	SEWER SERVICE SHALL BE CONSTRUCTED WITH A STRAIGHT GRADE AND ALIGNMENT FROM 1/8th BEND AT SEWER MAIN WYE TO THE EDGE OF THE R/W OR PUE. SEWER SERVICE SHALL BE CONSTRUCTED OF POLYVINYL CHLORIDE (PVC) SEWER PIPE (SDR 26) UNLESS OTHERWISE REQUIRED BY THE CITY ENGINEER.
4	SEWER SERVICE MANHOLE REQUIRED JUST INSIDE R/W OR PUE LINE. SEE CITY STANDARD DETAIL #407 FOR MANHOLE REQUIREMENTS AND DETAILS. MARKER BOLLARD NOT REQUIRED.
5	SEWER SERVICE TO BUILDING. IF NO BUILDING, PLACE SIX (6) INCH STUB FROM SERVICE MANHOLE WITH WATERTIGHT CAP.
6	THIRTY-SIX (36) INCHES MINIMUM COVER AT REQUIRED AT R/W OR PUE EDGE.
7	MARK ROADWAY CURB WITH A TWO (2) INCH LETTER "S" STAMPED, CHISLED, ECT. LOCATED DIRECTLY ABOVE WHERE THE SERVICE CROSSES THE GUTTER FLOW LINE. METHOD TO BE APPROVED BY THE CITY ENGINEER.

NOTES:

A. SEWER SERVICE CONSTRUCTION OF LARGER THAN EIGHT (8) INCHES IN DIAMETER MAY REQUIRE CONSTRUCTION OF A SECOND MANHOLE AT THE SEWER MAIN. DESIGN AND CONSTRUCTION OF MANHOLE SHALL MATCH STANDARD DETAIL #404 AND SUBMISSION AND APPROVAL OF THE PROPOSED SERVICE IS REQUIRED THE CITY ENGINEER.

B. SEWER SERVICE BEDDING AND INITIAL BACKFILL MATERIAL SHALL BE PER SECTION 12.05 OF THE CITY STANDARD CONSTRUCTION SPECIFICATIONS.

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #
401A

TITLE:
**COMMERCIAL/INDUSTRIAL/
MULTI-FAMILY SEWER
SERVICE MANHOLE**

