



LEFT SIDE VIEW

FRONT VIEW

NOTES:

- A. SIDEWALK BARRICADES TO BE ERECTED AT EACH LOCATION WHERE SATISFACTORY PROVISION CANNOT BE MADE FOR PEDESTRIANS TO CONTINUE BEYOND THE TERMINUS OF A SIDEWALK.
- B. ALL EXPOSED BARRICADE SURFACES TO BE PRIMED AND PAINTED WITH TWO (2) COATS OF WHITE PAINT CONFORMING TO SECTION 91-3.01 AND 91-3.02 OF THE STATE STANDARD SPECIFICATIONS.
- C. BOTTOM RAIL TO BE LOCATED NO HIGHER THAN 5" ABOVE ADJACENT PEDESTRIAN ACCESSIBLE ROUTE FINISHED SURFACE.
- D. BARRICADE WITH RETAINING WALL SHALL BE AS DETAILED IN STANDARD DETAIL 241. IF SLOPE TO GRADE CANNOT BE OBTAINED AND SUBJECT TO APPROVAL BY CITY ENGINEER.

①	2" x 6" DOUGLAS FIR OR HEM-FIR BOARDS (TYP)
②	4"x 4" x 5'-6" PRESSURE TREATED WOOD POSTS DESIGNED FOR DIRECT CONTACT WITH NATIVE SOIL / EARTH (TYP.)
③	½" GALVANIZED CARRIAGE BOLTS WITH WASHERS AND NUTS (TYP)

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #

242

TITLE:

**SIDEWALK
BARRICADE**

