



STREET LIGHT

FOUNDATION DETAIL

POLE DATA			ARM	FOUNDATION		ANCHOR BOLTS	
"A"	"P"	ACCEPTABLE PRODUCTS	"M"	"F"	RND	SIZE	BOLT CIRCLE
22'-6"	25' 0"	SEE CITY AUTHORIZED MATERIAL LIST	6'	5'-0"	30"Ø	1"x36"x4"	9"
27'-6"	30'-0"	SEE CITY AUTHORIZED MATERIAL LIST	6'	7'-0"	30"Ø	1"x36"x4"	9 1/2"
31'-7"	35'-0"	SEE CITY AUTHORIZED MATERIAL LIST	12'	7'-0"	30"Ø	1 1/4"x42"	12"

NOTES:

- A. STREETLIGHT POLES AND LUMINARY HEADS SHALL BE PER CITY AUTHORIZED MATERIAL LIST.
- B. PULL BOX SHALL BE INSTALLED ADJACENT TO POLE WITHIN 36". PULL BOX SHALL NOT BE LOCATED IN SIDEWALK WITHOUT PRIOR APPROVAL OF THE CITY ENGINEER.
- C. WHEN A SECONDARY PULL BOX IS LOCATED WITHIN 8' OF POLE, PULL BOX IS NOT REQUIRED.

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #

602

TITLE:

**STREET LIGHT
STANDARD**

