



CROSS SECTION

①	FINISH GRADE
②	MIN 3½ UTILITY PULL BOX WITH LOCKING COVER MARKED "STREET LIGHTS" PER CITY AUTHORIZED MATERIAL LIST OR APPROVED EQUAL.
③	PEA GRAVEL BACKFILL FOR DRAINAGE. PLACE FILTER FABRIC BETWEEN PEA GRAVEL AND SAND LAYER AS SHOWN.
④	PLACE SAND BACKFILL TO COMPLETELY COVER CONDUITS AND CONDUCTORS.
⑤	2" OF SLURRY CEMENT BACKFILL PER SECTION 37-3.02E OF THE STATE STANDARD SPECIFICATIONS OR MORTAR MIX WITH WRITTEN CITY APPROVAL.
⑥	RESERVED
⑦	MIN. 1" CONDUIT TO STREET LIGHT WITH #8 BARE BOND WIRE & CIRCUIT CONDUCTORS AS INDICATED ON THE PLANS. INSTALL DUCT SEALS IN ALL CONDUIT BENDS.
⑧	SIX (6) INCH BY SIX (6) CONCRETE COLLAR AROUND UTILITY BOX. CONCRETE SHALL BE MIN. 4,000 PSI MIX. SLOPE COLLAR AWAY FROM UTILITY BOX

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #
606

TITLE:
**STREET LIGHT
PULL BOX
AND
CONDUIT**

