



NOTES:

- A. BACKFILL MATERIAL SHALL BE AS REQUIRED IN DIVISION IV, SECTION 12.09 OF THE STANDARD SPECIFICATIONS:
 1. USE BACKFILL METHOD "A" IN EXISTING STREETS.
 2. USE BACKFILL METHOD "B" IN NEW CONSTRUCTION WITHIN THE STREET RIGHT-OF-WAY.
 3. USE BACKFILL METHOD "C" IN NEW CONSTRUCTION WITHIN NON-STREET RIGHT-OF-WAY.
- B. SELECT BACKFILL SHALL BE PLACED IN 8" MAXIMUM LOOSE LIFTS PRIOR TO COMPACTING EACH LIFT.
- C. FOR WATER MAIN INSTALLATION, SAND SHALL BE PLACED IN LIEU OF CRUSHED ROCK FOR PIPE BEDDING AND INITIAL BACKFILL.

NOTES (CONTINUED):

- D. PIPE BEDDING SHALL BE A MINIMUM OF 6 INCHES OR D/4 FOR ALL PIPES GREATER THAN 24 INCHES IN DIAMETER.
- E. ALTERNATE BACKFILL MATERIAL AND METHODS SHALL BE SUBJECT TO APPROVAL BY THE CITY ENGINEER.
- F. IF BOTTOM OF ROADWAY STRUCTURAL SECTION (SUBGRADE) IS 12" OR LESS FROM TOP OF INITIAL BACKFILL, FOLLOW SPECIAL TRENCH DETAILS SHOWN ON PLANS OR AS DIRECTED BY CITY ENGINEER.
- G. SEE STANDARD DETAIL 111 FOR MINIMUM AND MAXIMUM TRENCH WIDTH.

THE CITY OF WEST SACRAMENTO - STANDARD DETAIL



APPROVED: Aug. X, 2025

STANDARD
DETAIL #

110

TITLE:

TRENCH BACKFILL

