

SECTION 7 AGGREGATE BASE

7.01 DESCRIPTION

Aggregate base (AB) material and placement shall conform to Section 26 of the State Standard Specifications and shall be Class 2 AB as described in Sections 26-1.02A and 26-1.02B. Thickness shown on the plans shall be the minimum section allowed. Unless otherwise specified in Project Plans or Contract Specifications, three-quarters (3/4) inch maximum AB shall be used for all construction applications.

7.02 MEASUREMENT AND PAYMENT

Aggregate Base shall be measured by the cubic yard (CY) as calculated based on the dimensions shown on the plans adjusted by the amount of any change ordered by the City Engineer. No allowance will be made for aggregate base placed outside said dimensions or excess fill for low areas unless otherwise ordered by the City Engineer.

Payment will be made at the contract price per cubic yard (CY). Payment shall include full compensation for furnishing of all labor, materials, tools, equipment, and incidentals, and for doing all the work involved in constructing aggregate base, complete in place, as shown on the plans, and as specified in these specifications, and as directed by the City Engineer.